

# CERTIFICATE

Issued to:

Applicant:

**Seval Kablo Aydınlatma Cihaz  
ITH IHR SAN VE TIC A.S**  
Hacıyuplu Mah 3119, Sokak No 5  
20195 Denizli  
Turkey

Manufacturer/Licensee:

**Seval Kablo Aydınlatma Cihaz  
ITH IHR SAN VE TIC A.S**  
Hacıyuplu Mah 3119, Sokak No 5  
20195 Denizli  
Turkey

Product : Flexible cables with thermoplastic PVC insulation  
Trade name : SEVAL KABLO, SK, VOIFLEX  
Type : Ordinary duty cables: H05VV-F

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 50525-2-11:2011 clause 4.2
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2150792

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 2 July 2012 and expires upon withdrawal of one of the above mentioned standards.

**Certificate number: 2153349.02**

DEKRA Certification B.V.



drs. G.J. Zoetbrood  
Managing Director



H.R.M. Barends  
Certification Manager

© Integral publication of this certificate is allowed

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

ACCREDITED BY  
THE DUTCH COUNCIL  
FOR ACCREDITATION



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

product : Flexible cables with thermoplastic PVC insulation  
trade name : SEVAL KABLO, SK, VOIFLEX  
type : Ordinary duty cables: H05VV-F  
rated voltage : 300/500 V  
conductor : copper class 5  
insulation : PVC compound of type TI 2  
sheath : PVC compound of type TM 2

**Product data - type H05VV-F**

tested cords : 2x0,75mm<sup>2</sup> white sheathed  
5G2,5mm<sup>2</sup> black sheathed  
certified cords : 2-5x0,75-2,5mm<sup>2</sup> all colours

**TESTS****Test requirements**

EN 50525-2-11:2011 clause 4.2

**Test result**


The test results are laid down in DEKRA test file 2153349.02.

**Remarks**

The product has also a HAR TSE Certification no. TSE 00310 of 22 February 2010.

**Conclusion**

The examination proved that all test requirements were met.

Tested by : R. van Daalen 

Checked by : A.A. Mackenbach 

**Factory location**

Seval Kablo Aydinlatma Cihaz  
ITH IHR SAN VE TIC A.S  
Haciyuplu Mah 3119, Sokak No 5  
20195 Denizli  
Turkey