

CERTIFICATE

Issued to:
Applicant:
**Seval Kablo Aydınlatma Cihaz ITH IHR SAN VE
TIC A.S**
**Hacıyuplu Mah 3119
Sokak No 5
Uçler-Denizli
20195 Denizli, Turkey**

Licensee:
**Seval Kablo Aydınlatma Cihaz ITH IHR SAN VE
TIC A.S**
**Hacıyuplu Mah 3119
Sokak No 5
Uçler-Denizli
20195 Denizli, Turkey**

Product : XLPE insulated and PVC sheathed cables
Trade name(s) : SEVAL KABLO, SK, VOIFLEX or VOIKABEL
Type(s)/model(s) : YMvK and YMvK-ss

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard DEKRA K42D-1-1:2017 and DEKRA K42D-1-4-D:2017
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2150792


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 22 March 2019 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-101479

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: XLPE insulated and PVC sheathed cables
Trade name(s)	: SEVAL KABLO, SK, VOIFLEX or VOIKABEL
Type(s)/model(s)	: YMvK and YMvK-ss
Rated voltage	: 0,6/1kV
Conductor operating temperature	: 90°C maximum
Insulation	: XLPE compound
Inner covering	: Unvulcanized rubber or plastic compound (if applicable)
Sheath	: PVC compound of type PVC/ST

Product data – type YMvK

Conductor	: Plain copper class 2 (stranded shaped)
Certified cables	: 3x35 mm ² ~ 3x240 mm ² 4x35 mm ² ~ 4x240 mm ²

Product data – type YMvK

Conductor	: Plain copper class 1 and class 2 (circular)
Tested cables	: 3x2,5 mm ² and 1x240 mm ²
Certified cables	: 1-61x1,5 mm ² ~ 2,5 mm ² 1x1,5 mm ² ~ 1x1000 mm ² 2x1,5 mm ² ~ 2x300 mm ² 3x1,5 mm ² ~ 3x300 mm ² 4x1,5 mm ² ~ 4x300 mm ² 5x1,5 mm ² ~ 5x300 mm ²

Product data – type YMvK-ss

Conductor	: Plain copper, class 2 (circular)
Tested cables	: 3G10 mm ² and 4G70 mm ²
Certified cables	: 1x10 mm ² ~ 1x1000 mm ² 2x10 mm ² ~ 2x300 mm ² 3x10 mm ² ~ 3x300 mm ² 4x10 mm ² ~ 4x300 mm ² 5x10 mm ² ~ 5x300 mm ² 3x35 mm ² +1x25 mm ² ~ 3x240 mm ² +1x120 mm ² 4x35 mm ² +1x25 mm ² ~ 4x95 mm ² +1x50 mm ²

TESTS**Test requirements**

DEKRA K42D-1-1:2017
DEKRA K42D-1-4-D:2017

Test result

The test results are laid down in DEKRA test file 216702800 and 221869800.

Additional information

This certificate replaces certificate No. 2167028.01 which we herewith declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory location

Seval Kablo Aydınlatma Cihaz ITH IHR SAN VE TIC A.S
Hacıyuplu Mah 3119
Sokak No 5
Uçler-Denizli
20195 Denizli, Turkey